



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Forest Court NCU  
Forest Way  
Tatchbury Mount  
Calmore, Totton SO40 2PZ

**Customer:** Hampshire County Council

**Date:** 27<sup>th</sup> May 2011

**System Type and Location:** Cold Water Storage Tank – Roof Space above Primrose Wing

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical Level @ Start = 500ppm  
Chemical Level @ 10 minutes = 500ppm  
Chemical Level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:  
[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Forest Court NCU  
Forest Way  
Tatchbury Mount  
Calmore, Totton SO40 2PZ

**Customer:** Hampshire County Council

**Date:** 27<sup>th</sup> May 2011

**System Type and Location:** Cold Water Storage Tank – Roof Space above Primrose Wing

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical Level @ Start = 500ppm  
Chemical Level @ 10 minutes = 500ppm  
Chemical Level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:  
[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION