



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: John Darling Mall
Selbourne Drive
Eastleigh
SO50 4SE

Customer: Hampshire County Council

Date: 24 October 2012

System Type and Location: Cold water storage tank – above laundry

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ finish = as mains

Scope of Work Completed: ACoP L8

Freeton Water Treatment Limited

A handwritten signature in black ink, appearing to read "Kari", is written over a horizontal dotted line.

(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION