



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Romsey & Waterside Day Services
Jacobs Gutter Lane
Hounslow
SO40 9FT

Customer: Hampshire County Council

Date: 15 October 2012

System Type and Location: Cold water storage tank – kitchen cupboard

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ finish = as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION