



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001/BS6700:2006

Site: Meadowcroft
Whitchurch Close
Aldershot
Hampshire GU11 3RU

Customer: Hampshire County Council

Date: 3rd October 2011

System Type and Location: Hot & cold water services throughout

Disinfecting Product: Sodium Hypochlorite

Contact Time: (hours) Chemical Level @ Start = 50ppm
Chemical level @30 minutes = 50ppm
Chemical Level @ 60 Mins = 50ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: System disinfected and flushed to BS6700:2006 specification

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION