



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001/BS6700:2006

Site: Solent Mead OPH
Church Lane
Lymington
Hampshire

Customer: Hampshire County Council

Date: 24th April 2012

System Type and Location: Arjo Bath & associated assets to Rowan Wing bathroom

Disinfecting Product: Sodium Hypochlorite Solution

Contact Time: Chemical Level @ start = 60ppm
Chemical level @ 30 minutes = 60ppm
Chemical Level @ 60 minutes = 60ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: System disinfected and flushed to BS6700:2006 specification

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION