



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Clere School & Technology College
Burghclere
Newbury
RG20 9HP

Client: Kier Services

Date: 22 - 23 June 2013

System Type and Location: Cold Water Storage Tank 1 – roof front tank room

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start \geq 50ppm
Chemical Level @ 30 minutes \geq 50ppm
Chemical Level @ 1 hour \geq 50ppm
Chemical Level on completion; as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Clere School & Technology College
Burghclere
Newbury
RG20 9HP

Client: Kier Services

Date: 22 - 23 June 2013

System Type and Location: Cold Water Storage Tank 2 – roof front tank room

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start \geq 50ppm
Chemical Level @ 30 minutes \geq 50ppm
Chemical Level @ 1 hour \geq 50ppm
Chemical Level on completion; as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Clere School & Technology College
Burghclere
Newbury
RG20 9HP

Client: Kier Services

Date: 22 - 23 June 2013

System Type and Location: Cold Water Storage Tank 3 – roof rear tank room

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start \geq 50ppm
Chemical Level @ 30 minutes \geq 50ppm
Chemical Level @ 1 hour \geq 50ppm
Chemical Level on completion; as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Clere School & Technology College
Burghclere
Newbury
RG20 9HP

Client: Kier Services

Date: 22 - 23 June 2013

System Type and Location: Cold Water Storage Tank 4 – roof rear tank room

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start \geq 50ppm
Chemical Level @ 30 minutes \geq 50ppm
Chemical Level @ 1 hour \geq 50ppm
Chemical Level on completion; as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION