



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Ticehurst
Whitchurch Close
Aldershot
Hampshire GU11 3RX

Customer: Hampshire County Council

Date: 01 August 2013

System Type and Location: Hot & cold supply to Bickerley Wing bathroom

Disinfecting Product: Chlorine Dioxide Solution

Contact Time: Chemical Level @ Start \geq 50ppm
Chemical Level @ 30 minutes \geq 50ppm
Chemical Level @ 1 hour \geq 50ppm
Chemical Level on completion; as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Oakridge OPH
Jefferson Road
Basingstoke
Hampshire RG21 5QS

Customer: Hampshire County Council

Date: 11 July 2013

System Type and Location: Hot & cold supply to Tadley Wing bathroom

Disinfecting Product: Sodium Hypochlorite Solution

Contact Time: Chemical Level @ Start \geq 50ppm
Chemical Level @ 30 minutes \geq 50ppm
Chemical Level @ 1 hour \geq 50ppm
Chemical Level on completion; as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION