

---

## TEST REPORT

---

Sender: Freeston Water Treatment  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton SO40 3WW

Date Collected: 14/02/2013  
Date Received: 14/02/2013  
Sample Details: [PO/BWF/QAB](#)

---

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
<b>QAB Tank 1</b>	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	4	cfu/ml
	TVC (3 Days @ 22°C)	0	cfu/ml
<b>QAB Tank 2</b>	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	0	cfu/ml
	TVC (3 Days @ 22°C)	0	cfu/ml
<b>QAB Main 1</b>	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	0	cfu/ml
	TVC (3 Days @ 22°C)	49	cfu/ml
<b>QAB Main 2</b>	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	0	cfu/ml
	TVC (3 Days @ 22°C)	0	cfu/ml
<b>QAB Tank 1 Outlet 1</b>	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	1	cfu/ml
	TVC (3 Days @ 22°C)	990	cfu/ml
<b>QAB Tank 1 Outlet 2</b>	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	0	cfu/ml
	TVC (3 Days @ 22°C)	17	cfu/ml

---

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS  
Accredited Laboratory (Reg. No. 0996)

---

DATE PRINTED: 28<sup>th</sup> February 2013

---

---

## TEST REPORT

---

Sender: Freeston Water Treatment  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton SO40 3WW

Date Collected: 14/02/2013  
Date Received: 14/02/2013  
Sample Details: [PO/BWF/QAB](#)

---

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
<a href="#">QAB Tank 2 Outlet</a>	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	10	cfu/ml
	TVC (3 Days @ 22°C)	380	cfu/ml

---

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

---

DATE PRINTED: 28<sup>th</sup> February 2013

---