
TEST REPORT

Sender: Freeston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 10/01/2013
Date Received: 11/01/2013
Sample Details: [PO/BWF](#)

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
QAB Main 1	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	0	cfu/ml
	TVC (3 Days @ 22°C)	0	cfu/ml
QAB Tank 1	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	1	cfu/ml
	TVC (3 Days @ 22°C)	0	cfu/ml
QAB Outlet 1	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	0	cfu/ml
	TVC (3 Days @ 22°C)	5400	cfu/ml
QAB Outlet 2 from Tank 1	Escherichia coli	300	cfu/100ml
	Total Coliforms	600	cfu/100ml
	TVC (2 Days @ 37°C)	4	cfu/ml
	TVC (3 Days @ 22°C)	220	cfu/ml
QAB Main 2	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	0	cfu/ml
	TVC (3 Days @ 22°C)	3	cfu/ml
QAB Tank 2	Escherichia coli	0	cfu/100ml
	Total Coliforms	0	cfu/100ml
	TVC (2 Days @ 37°C)	0	cfu/ml
	TVC (3 Days @ 22°C)	1	cfu/ml

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS
Accredited Laboratory (Reg. No. 0996)

DATE PRINTED: 22nd January 2013

TEST REPORT

Sender: Freeston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 10/01/2013
Date Received: 11/01/2013
Sample Details: **PO/BWF**

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
QAB Outlet 2 from Tank 2	Escherichia coli	0	cfu/100ml
	Total Coliforms	1	cfu/100ml
	TVC (2 Days @ 37°C)	31	cfu/ml
	TVC (3 Days @ 22°C)	4400	cfu/ml

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

DATE PRINTED: 22nd January 2013
