



## WORK REPORT

Freston Water Treatment Ltd  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
SO40 3WW  
Telephone: 023 8066 9713  
Email: [info@freston.co.uk](mailto:info@freston.co.uk)

### CLIENT DETAILS:

Order Ref: **Alan Tribbeck**  
Client Contact: Chris Price  
Address:  
Marina Developments Limited  
Queen Anne Battery  
Plymouth  
PL4 0LP  
Tel: 01752 671 142

### SITE DETAILS:

Site Contact: Chris Price  
Address:  
Marina Developments Limited  
Queen Anne Battery  
Plymouth  
PL4 0LP  
Tel: 01752 671 142

14 August 2013 -

Attended site and carried out the following work:

Collected 7 x bacterial samples as per Certificate of Analysis (uploaded to the QAB area on the Freston website <https://sites.google.com/a/freston.co.uk/website/clients-files/marina-developments/queen-anne-battery-plymouth>)

The following samples were returned as unsatisfactory:

- *Yacht Club Rear Entrance Hose*
- *Yellow North Berth 24*
- *North Wall – Last hose on the right before road*

Each outlet should be **thoroughly cleaned/disinfected and flushed immediately**. If not used at least weekly then twice weekly flushing should be introduced.

Resample should be considered once the above has taken place. The samples from the tanks are ok so the above results are from a lack of use and general cleanliness.

Client Signature:

Print Name: C Price  
Date: 31 August 2013

Freston Water Treatment Signature:

  
Print Name: Karl Gailer  
Date: 31 August 2013