



WORK REPORT

Freston Water Treatment Ltd
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
SO40 3WW
Telephone: 023 8066 9713
Email: info@freston.co.uk

CLIENT DETAILS:

Order Ref: **Alan Tribbeck**
Client Contact: Chris Price
Address:
Marina Developments Limited
Queen Anne Battery
Plymouth
PL4 0LP
Tel: 01752 671 142

SITE DETAILS:

Site Contact: Chris Price
Address:
Marina Developments Limited
Queen Anne Battery
Plymouth
PL4 0LP
Tel: 01752 671 142

02 May 2013 -

Attended site and carried out the following work:

Collected 7 x bacterial samples as per Certificate of Analysis (uploaded to the QAB area on the Freston website <https://sites.google.com/a/freston.co.uk/website/clients-files/marina-developments/queen-anne-battery-plymouth>)

Sample taken from Berth 88 hose reel is above the EU drinking water parameters, the remaining results were satisfactory

Cold water temperatures recorded from all locations were below 20°C

Client Signature:

Print Name: R Berry
Date: 02 May 2013

Freston Water Treatment Signature:

Print Name: Karl Gailer
Date: 02 May 2013