



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Brooks Shopping Centre
Winchester
Hampshire
SO23 8QY

Customer: London & Henley (Winchester) Ltd

Date: 16 July 2013

System Type and Location: Fortic Hot Water Heater (Integral Header Tank)
Cleaner Room

Disinfecting Product: Chlorine Dioxide Solution

Contact Time: Chemical Level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: System disinfected to ACoP L8 specification

Freeton Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Brooks Shopping Centre
Winchester
Hampshire
SO23 8QY

Customer: London & Henley (Winchester) Ltd

Date: 16 July 2013

System Type and Location: Sadia Hot Water Heater (Integral Header Tank)
Baby Changing Room

Disinfecting Product: Chlorine Dioxide Solution

Contact Time: Chemical Level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: System disinfected to ACoP L8 specification

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Brooks Shopping Centre
Winchester
Hampshire
SO23 8QY

Customer: London & Henley (Winchester) Ltd

Date: 16 July 2013

System Type and Location: Sadia Hot Water Heater (Integral Header Tank)
Engineers Suite

Disinfecting Product: Chlorine Dioxide Solution

Contact Time: Chemical Level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: System disinfected to ACoP L8 specification

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Brooks Shopping Centre
Winchester
Hampshire
SO23 8QY

Customer: London & Henley (Winchester) Ltd

Date: 16 July 2013

System Type and Location: Sadia Hot Water Heater (Integral Header Tank)
Ladies Public Toilet

Disinfecting Product: Chlorine Dioxide Solution

Contact Time: Chemical Level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: System disinfected to ACoP L8 specification

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Brooks Shopping Centre
Winchester
Hampshire
SO23 8QY

Customer: London & Henley (Winchester) Ltd

Date: 16 July 2013

System Type and Location: Sadia Hot Water Heater (Integral Header Tank)
Management Suite Kitchen

Disinfecting Product: Chlorine Dioxide Solution

Contact Time: Chemical Level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: System disinfected to ACoP L8 specification

Freeton Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION