



WORK REPORT

Freston Water Treatment Ltd
 Unit 1, Lulworth Business Centre
 Nutwood Way, Calmore Industrial Estate
 Totton, Southampton
 SO40 3WW
 Telephone: 023 8066 9713
 Email: info@freston.co.uk

CLIENT DETAILS:

Order Ref: **BC/2013/16**
 Client Contact: Bob Bullwinkle
 Address:
 London & Henley (Winchester) Ltd
 The Brooks Shopping Centre
 Winchester
 SO23 8QY
 Telephone No. 01962 849 030

SITE DETAILS:

Site Contact: Bob Bullwinkle
 Address:
 London & Henley (Winchester) Ltd
 The Brooks Shopping Centre
 Winchester
 SO23 8QY
 Telephone No. 01962 849 030

All applicable documentation has been uploaded to The Brooks client area on the Freston Water Treatment Ltd website.

16 July 2013:

Attended site and carried out the following –

Collected samples from the following systems:

Plant room 1 – LTHW

Plant room 1 – closed system

Analytical report certificate of conformity uploaded to The Brooks client area.

Potable water Sampling -

Sample Point	Sample ref	Legionella	Satisfactory
Level 3 staff wc	JM0658	X	Yes
Loading Bay Tap	JM0659	X	Yes

Sample Point	Sample ref	Bacterial	Satisfactory
Level 3 staff wc	JM0660	X	Yes
Loading Bay Tap	JM0661	X	Yes

Please refer to the uploaded certificates of analysis

Cleaned & disinfected the following hot water heater header tanks to ACoP L8

Cleaners Room
Baby Change
Engineers Suite
Ladies Public WC
Management Suite

Please refer to the uploaded certificates of disinfection


Prepared & delivered 1no legionella / water hygiene management logbook (31/07/2013)

Water Hygiene Operatives: Paul Harrison & Simon Harvey

Client Signature:

Print Name: B Bullwinkle
Date: 30 July 2013

Freeston Water Treatment Signature:


Print Name: Karl Gailer
Date: 30 July 2013