

At the time of the monthly visit on **19/4/2018**, within one minute these **hot water** outlet temperatures were recorded and within two minutes these **cold water** outlet temperatures were recorded: -

<u>B&Q DATA CENTRE</u>				
FAREHAM				
Asset Ref.	Outlet	HOT °C	COLD °C	COMMENTS
GROUND FLOOR				
00036/00035	Kitchen	55.2	12.1	
00033	WC	58.4	12.1	
00031	Disabled WC	60.4	12.3	
FIRST FLOOR				
00030/00029	UNISEX WC	50.5	12.2	

<u>B&Q HOUSE</u>				
CHANDLERS FORD				
Asset Ref.	Outlet	HOT °C	COLD °C	COMMENTS
GROUND FLOOR				
09089/09088	Core 11 Cleaners	60.7	12.8	
09069	Main Kitchen	54.5	15.1	
00012/00013	Core 10 Tea	57.2	16.8	
0021/0020	Coffee Shop	60.3	16.6	
10204	Core 7 Tea	61.8	16.5	
10199/10200	Core 8 Cleaners	65.6	14.5	
10039	Core 9 Tea	72.6	14.8	
	Gym Men	54.5	40.9	14.5
	PLANT ROOM	FLOW RETURN		
	Calorifier 1	58.0		
	Calorifier 2	55.0		

Asset Ref.	Outlet	HOT °C		COLD °C	COMMENTS
FIRST FLOOR					
09075/09074	Core 11 Cleaners	57.5		12.8	
10336/10337	Core 7 Cleaners	60.0		12.5	
10379	Core 7 Tea	56.0	47.6	16.7	
09078	Core 8 Tea	65.6	52.0	13.6	
10402	Core 9 Tea	63.0	52.2	15.0	
0016/0017	Core 10 Tea	60.6	49.2	19.9	
	Rest Room	43.0		19.6	INCREASE HOT TO MIN 50°C
	C Kitchen 1	54.0		12.9	
	C Kitchen 2				
SECOND FLOOR					
09083/09082	Core 10 Tea	63.5	52.1	20.0	
09081/09080	Core 7 Cleaners	60.0		12.2	
0014/0015	Core 7 Tea	57.0	48.4	15.5	
09086/09087	Core 8 Tea	73.7	53.4	15.6	
09084/09085	Core 9 Tea	64.9	50.3	16.2	
Q/A LAB					
09093/09092	Cleaners Sink				
	Q/A Lab	ZIP OK			

Non Conformities are in Red

L8 recommends cold water should be stored and distributed at no more than 20°C.

L8 recommends that the hot water should be stored at a minimum of 60°C and achieve 50°C, obtainable at user outlets within one minute of opening.