

At the time of the monthly visit on **22/5/2018**, within one minute these **hot water** outlet temperatures were recorded and within two minutes these **cold water** outlet temperatures were recorded: -

<b><u>B&amp;Q DATA CENTRE</u></b>				
FAREHAM				
Asset Ref.	Outlet	HOT °C	COLD °C	COMMENTS
<b>GROUND FLOOR</b>				
00036/00035	Kitchen	52.8	16.6	
00033	WC	58.0	16.7	
00031	Disabled WC	60.0	16.8	
<b>FIRST FLOOR</b>				
00030/00029	UNISEX WC	54.2	16.8	
<b><u>B&amp;Q HOUSE</u></b>				
CHANDLERS FORD				
Asset Ref.	Outlet	HOT °C	COLD °C	COMMENTS
<b>GROUND FLOOR</b>				
09089/09088	Core 11 Cleaners	54.6	16.2	
09069	Main Kitchen	52.9	16.0	
00012/00013	Core 10 Tea	47.6	21.0	Increase Hot to Min 50°C Flush Cold to Below 20°C
0021/0020	Coffee Shop	52.0	18.2	
10204	Core 7 Tea	57.8	18.8	
10199/10200	Core 8 Cleaners	48.9	16.2	Increase to Min 50°C
10039	Core 9 Tea	70.5	18.2	
	Gym Ladies	52.3	41.6	17.6
	PLANT ROOM	FLOW	RETURN	
	Calorifier 1	58.0		Increase to minimum 60°C
	Calorifier 2	54.0		Increase to minimum 60°C

Asset Ref.	Outlet	HOT °C		COLD °C	COMMENTS
<b>FIRST FLOOR</b>					
09075/09074	Core 11 Cleaners	58.6		16.2	
10336/10337	Core 7 Cleaners	53.5		15.4	
10379	Core 7 Tea	54.3	48.0	16.0	
09078	Core 8 Tea	62.3	50.0	17.2	
10402	Core 9 Tea	62.8	50.6	17.6	
0016/0017	Core 10 Tea	55.1	48.4	20.8	
	Rest Room	47.5		22.4	Increase Hot to Min 50°C Flush Cold to Below 20°C
	C Kitchen 1	58.0		15.4	
	C Kitchen 2				
<b>SECOND FLOOR</b>					
09083/09082	Core 10 Tea	55.0	48.9	20.9	Flush to Below 20°C
09081/09080	Core 7 Cleaners	55.9		15.2	
0014/0015	Core 7 Tea	50.0	47.6	18.4	
09086/09087	Core 8 Tea	66.3	52.0	17.6	
09084/09085	Core 9 Tea	63.2	50.3	18.0	
<b>Q/A LAB</b>					
09093/09092	Cleaners Sink				
	Q/A Lab	ZIP OK			

**Non Conformities are in Red**

**L8 recommends cold water should be stored and distributed at no more than 20°C.**

**L8 recommends that the hot water should be stored at a minimum of 60°C and achieve 50°C, obtainable at user outlets within one minute of opening.**