



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: H+S Aviation
Robinson Way
Portsmouth PO3 5TH

Customer: H+S Aviation

Our Reference: Steve Conway

Date: 8th March 2013

System Type and Location: Process Cooling Tower

Disinfecting Product: Chlorine Dioxide

Contact Time: (hours) Chemical level @ start = 50+ppm
Chemical level @ 60 mins – 50+ppm
Chemical Level @ Finish As Main

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk

