
TEST REPORT

Sender: Freeston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 21/03/2013
Date Received: 21/03/2013
Sample Details: **Legionella**

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
SP/CT/7307 New	Legionella spp	Not Detected	cfu/l
SP/CT/7308 Large	Legionella spp	Not Detected	cfu/l
SP/CT/7309 Small Left	Legionella spp	Not Detected	cfu/l
SP/CT/7310 Small Right	Legionella spp	Not Detected	cfu/l
SP/CT/7311 Ally 1	Legionella spp	Not Detected	cfu/l

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

DATE PRINTED: 3rd April 2013
