

---

## TEST REPORT

---

Sender: Freeston Water Treatment  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton SO40 3WW

Date Collected: 15/08/2013  
Date Received: 15/08/2013  
Sample Details: [PO/CT/7410](#)

---

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
<a href="#">SP/CT/7472 New</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7473 Large</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7474 Small Left</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7475 Small Right</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7476 Ally 1</a>	Legionella spp	Not Detected	cfu/l

---

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

---

DATE PRINTED: 30<sup>th</sup> August 2013

---