
TEST REPORT

Sender: Freeston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 15/08/2013
Date Received: 15/08/2013
Sample Details: [PO/CT/7410](#)

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
SP/CT/7466 1 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7467 3 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7468 4 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7469 5 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7470 EAB	Legionella spp	Not Detected	cfu/l
SP/CT/7471 Process	Legionella spp	Not Detected	cfu/l

Comments:

Reduced volume filtered due to turbidity of sample

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

DATE PRINTED: 30th August 2013
