
TEST REPORT

Sender: Freeston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 16/05/2013
Date Received: 17/05/2013
Sample Details: [PO/CT/7354](#)

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
SP/CT/7354 1 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7355 3 Bed	Legionella spp	Not Detected	cfu/l
	Due to sample turbidity this sample has been filtered at a reduced volume.		
SP/CT/7356 4 Bed	Legionella spp	Not Detected	cfu/l
	Due to sample turbidity this sample has been filtered at a reduced volume		
SP/CT/7357 5 Bed	Legionella spp	Not Detected	cfu/l
	Due to sample turbidity this sample has been filtered at a reduced volume		
SP/CT/7358 EAB	Legionella spp	Not Detected	cfu/l
	Due to sample turbidity this sample has been filtered at a reduced volume		
SP/CT/7359 Process	Legionella spp	Not Detected	cfu/l

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

DATE PRINTED: 31st May 2013
