

---

## TEST REPORT

---

Sender: Freeston Water Treatment  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton SO40 3WW

Date Collected: 21/03/2013  
Date Received: 21/03/2013  
Sample Details: [PO/CT/7887](#)

---

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
<a href="#">SP/CT/7297 1 Bed</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7298 3 Bed</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7299 4 Bed</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7300 5 Bed</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7301 EAB</a>	Legionella spp	Not Detected	cfu/l
<a href="#">SP/CT/7302 Process</a>	Legionella spp	Not Detected	cfu/l

---

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

---

DATE PRINTED: 5<sup>th</sup> April 2013

---