
TEST REPORT

Sender: Freeston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 21/11/2013
Date Received: 21/11/2013
Sample Details: [PO/CT/7422](#)

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
SP/CT/7513 1 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7514 3 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7515 4 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7516 5 Bed	Legionella spp	Not Detected	cfu/l
SP/CT/7517 EAB	Legionella spp	Not Detected	cfu/l
SP/CT/7518 Process	Legionella spp	Not Detected	cfu/l
SP/CT/7519 Ally 1	Legionella spp	Not Detected	cfu/l
SP/CT/7520 New	Legionella spp	Not Detected	cfu/l
SP/CT/7521 Large	Legionella spp	Not Detected	cfu/l
SP/CT/7522 Small Left	Legionella spp	Not Detected	cfu/l
SP/CT/7523 Small Right	Legionella spp	Not Detected	cfu/l

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

DATE PRINTED: 16th December 2013
