



Freston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freston.co.uk
Web: www.freston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2013/BS8558:2011

Site: Airport Service Road
Portsmouth
Hampshire
PO3 5PJ

Customer: H+S Aviation Ltd

Date: 15 October 2016

System Type and Location: Small Tank Storage Cage Area

Disinfecting Product: Chlorine Dioxide

Contact Time: Free Residual Chlorine Level @ Start = 500ppm
Free Residual Chlorine Level @ 30 Mins = Minutes 10=
500ppm
Free Residual Chlorine Level @ 60 Mins =
Free Residual Chlorine Level on Completion = As Mains

Scope of Work Completed: System disinfected and flushed to BS8558:2011 specification

Freston Water Treatment:

(Authorised Signatory)

www.freston.co.uk



Legionella
Control
Association

KEEPING WATER SYSTEMS SAFE