



Freston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freston.co.uk](mailto:info@freston.co.uk)  
Web: [www.freston.co.uk](http://www.freston.co.uk)

## CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2013/BS8558:2011

**Site:** Airport Service Road  
Portsmouth  
Hampshire  
PO3 5PJ

**Customer:** H+S Aviation Ltd

**Date:** 15 October 2016

**System Type and Location:** Main Tank Office Space

**Disinfecting Product:** Chlorine Dioxide

**Contact Time:** Free Residual Chlorine Level @ Start = 500ppm  
Free Residual Chlorine Level @ 30 Mins = Minutes 10=  
500ppm  
Free Residual Chlorine Level @ 60 Mins =  
Free Residual Chlorine Level on Completion = As Mains

**Scope of Work Completed:** System disinfected and flushed to BS8558:2011 specification

**Freston Water Treatment:**

(Authorised Signatory)

[www.freston.co.uk](http://www.freston.co.uk)

