



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

COOLING TOWERS

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2013/HSG274

Site:

H&S Aviation
Airport Service Road
Portsmouth
Hampshire
PO23 6LG

Date: 20 April 2016

System Type and Location: Tower 1

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start = 60ppm
Chemical Level @ 60 minutes = 60ppm
Chemical Level @ Finish = 60ppm

Scope of Work Completed: In Accordance with Method Statement

Freeston Water Treatment:

(Authorised Signatory)

www.freeston.co.uk

