
TEST REPORT

Sender: Freeston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 15/07/2016
Date Received: 15/07/2016
Sample Details: [PO/CT/796](#)

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
GE	COD	465	mg/l
	Oil and Grease	5.93	mg/l
	pH	9.6	
	Suspended Solids at 105°C	200	mg/l
	Zinc (Zn)	0.107	mg/l
CBAY	Chromium	0.269	mg/l
	COD	59	mg/l
	Nickel	0.797	mg/l
	Oil and Grease	3.35	mg/l
	pH	8.7	
	Suspended Solids at 105°C	42	mg/l
APU	COD	12	mg/l
	Copper	<0.009	mg/l
	Lead	<0.006	mg/l
	Oil and Grease	<0.2	mg/l
	pH	8.6	
	Suspended Solids at 105°C	8	mg/l
	Zinc (Zn)	0.03	mg/l

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 1111)

DATE PRINTED: 18th April 2016
