
TEST REPORT

Sender: Freston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 18/02/2016
Date Received: 18/02/2016
Sample Details: [PO/CT/700](#)

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
1 Bed	Legionella spp	Not Detected	cfu/l
3 Bed	Legionella spp	Not Detected	cfu/l
4 Bed	Legionella spp	Not Detected	cfu/l

Comments:

This sample was tested at a reduced volume of 200ml for Legionella analysis due to particulate content.

5 Bed	Legionella spp	Not Detected	cfu/l
EAB	Legionella spp	Not Detected	cfu/l
Process	Legionella spp	Not Detected	cfu/l
Ally	Legionella spp	Not Detected	cfu/l
New Paint	Legionella spp	Not Detected	cfu/l
Large Paint	Legionella spp	Not Detected	cfu/l
Small Left Paint	Legionella spp	Not Detected	cfu/l
Small Right Paint	Legionella spp	Not Detected	cfu/l

The above analysis has been carried out for Freston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 1349)

DATE PRINTED: 2 March 2016
