

---

## TEST REPORT

---

Sender: Freeston Water Treatment  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton SO40 3WW

Date Collected: 24/11/2016  
Date Received: 24/11/2016  
Sample Details: [PO/CT/741](#)

---

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
1 Bed	Legionella spp	Not Detected	cfu/l
3 Bed	Legionella spp	Not Detected	cfu/l
4 Bed	Legionella spp	Not Detected	cfu/l

Comments:

This sample was tested at a reduced volume of 200ml for Legionella analysis due to particulate content.

5 Bed	Legionella spp	Not Detected	cfu/l
EAB	Legionella spp	Not Detected	cfu/l
PRO	Legionella spp	Not Detected	cfu/l
ALLY	Legionella spp	Not Detected	cfu/l
NEW	Legionella spp	Not Detected	cfu/l
LARGE	Legionella spp	Not Detected	cfu/l

Comments:

This sample was tested at a reduced volume of 200ml for Legionella analysis due to particulate content.

S/L	Legionella spp	Not Detected	cfu/l
-----	----------------	--------------	-------

---

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 1349)

---

DATE PRINTED: 8<sup>th</sup> December 2016

---

---

## TEST REPORT

---

Sender: Freeston Water Treatment  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton SO40 3WW

Date Collected: 24/11/2016  
Date Received: 24/11/2016  
Sample Details: [PO/CT/741](#)

---

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
<a href="#">S/R</a>	Legionella spp	Not Detected	cfu/l

---

---

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 1349)

---

DATE PRINTED: 8<sup>th</sup> December 2016

---