
TEST REPORT

Sender: Freston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 18/02/2016
Date Received: 18/02/2016
Sample Details: [PO/CT/701](#)

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
GE	pH	9.04	
	Suspended Solids	62.0	mg/l
	COD (Chemical Oxygen Demand)	26.00	mg/l
	Zinc	91.9	mg/l
	Total Oil and Grease	29.1	mg/l
CBAY	pH	8.28	
	Suspended Solids	48.0	mg/l
	COD (Chemical Oxygen Demand)	207.00	mg/l
	Chromium	380.00	mg/l
	Nickel	1070.00	µg/l Ni
	Total Oil and Grease	15.1	mg/l
APU	pH	7.92	
	Suspended Solids	93.3	mg/l
	COD (Chemical Oxygen Demand)	311.00	mg/l
	Copper	77.53	mg/l
	Lead	24.30	mg/l
	Zinc	202	mg/l
	Total Oil and Grease	6.3	mg/l

The above analysis has been carried out for Freston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 1349)

DATE PRINTED: 5 May 2016
