
TEST REPORT

Sender: Freston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 17/03/2016
Date Received: 17/03/2016
Sample Details: [PO/CT/752](#)

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
GE	pH	8.54	
	Suspended Solids	52.0	mg/l
	COD (Chemical Oxygen Demand)	190	mg/l
	Zinc	0.124	mg/l
	Total Oil and Grease	20.7	mg/l
CBAY	pH	8.22	
	Suspended Solids	49.0	mg/l
	COD (Chemical Oxygen Demand)	204	mg/l
	Chromium	0.130	mg/l
	Nickel	<4	µg/l Ni
	Total Oil and Grease	14.5	mg/l
APU	pH	7.99	
	Suspended Solids	<5	mg/l
	COD (Chemical Oxygen Demand)	<10.8	mg/l
	Copper	<0.0055	mg/l
	Lead	<5	mg/l
	Zinc	0.129	mg/l
	Total Oil and Grease	5.3	mg/l

The above analysis has been carried out for Freston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 1349)

DATE PRINTED: 5 May 2016
