

---

## TEST REPORT

---

Sender: Freeston Water Treatment  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton SO40 3WW

Date Collected: 19/05/2016  
Date Received: 19/05/2016  
Sample Details: [PO/CT/778](#)

---

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
1 Bed	Legionella spp	Not Detected	cfu/l
3 Bed	Legionella spp	Not Detected	cfu/l
4 Bed	Legionella spp	Not Detected	cfu/l
5 Bed	Legionella spp	Not Detected	cfu/l
EAB	Legionella spp	Not Detected	cfu/l
Process	Legionella spp	Not Detected	cfu/l
Ally	Legionella spp	Not Detected	cfu/l
New	Legionella spp	Not Detected	cfu/l
Large	Legionella spp	Not Detected	cfu/l
Small Left	Legionella spp	Not Detected	cfu/l
Small Right	Legionella spp	Not Detected	cfu/l

---

The above analysis has been carried out for Freeston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 1349)

---

DATE PRINTED: 2 June 2016

---