

CERTIFICATE OF ANALYSIS

Sender: Freeston Water Treatment Ltd
Unit 1, Lulworth Business Centre
Nutwood Way
Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 16/03/2019
Date Tested: 16/03/2019
Sample Details: CT777

Sample Reference	Test	Results	Units
GE	COD Whole Sample	382	mg/l O2
	pH	8.86	pH value
	Suspended Solids at 105°C	39	mg/l
	Fats Oils & Grease	27.3	mg/l
	Total Zinc	<0.08	mg/l Zn
CBAY	COD Whole Sample	10.2	mg/l O2
	pH	8.06	pH value
	Suspended Solids at 105°C	<7.65	mg/l
	Fats Oils and Grease	0.88	mg/l
	Total Chromium	0.167	mg/l Cr
	Total Nickel	0.134	mg/l Ni
APU	COD Whole Sample	<9.8	mg/l O2
	pH	8.52	pH value
	Suspended Solids at 105°C	32	mg/l
	Fats Oils and Grease	0.71	mg/l
	Total Copper	0.057	mg/l Cu
	Total Lead	0.03	mg/l Pb
	Total Zinc	0.41	mg/l Zn

The above analysis has been carried out for Freeston Water Treatment Limited
by an Independent UKAS Accredited Laboratory (Reg. No.9658)

DATE PRINTED:10th April 2019
