

CERTIFICATE OF ANALYSIS

Sender: Freeston Water Treatment Ltd
Unit 1, Lulworth Business Centre
Nutwood Way
Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 22/01/2019
Date Tested: 22/01/2019
Sample Details: CT/768

Sample Reference	Test	Results	Units
GE	COD Whole Sample	306	mg/l O2
	pH	8.4	pH value
	Suspended Solids at 105°C	80	mg/l
	Fats Oils & Grease	29.7	mg/l
	Total Zinc	0.11	mg/l Zn
CBAY	COD Whole Sample	509	mg/l O2
	pH	8.31	pH value
	Suspended Solids at 105°C	38	mg/l
	Fats Oils and Grease	25.5	mg/l
	Total Chromium	0.221	mg/l Cr
	Total Nickel	0.614	mg/l Ni
APU	COD Whole Sample	16.2	mg/l O2
	pH	8.17	pH value
	Suspended Solids at 105°C	8	mg/l
	Fats Oils and Grease	<0.60	mg/l
	Total Copper	0.018	mg/l Cu
	Total Lead	<0.02	mg/l Pb
	Total Zinc	<0.08	mg/l Zn

The above analysis has been carried out for Freeston Water Treatment Limited
by an Independent UKAS Accredited Laboratory (Reg. No.9658)

DATE PRINTED: 6th February 2019
