

At the time of the monthly visit on **15/2/2018**, within one minute these **hot water** outlet temperatures were recorded and within two minutes these **cold water** outlet temperatures were recorded: -

<u>B&Q DATA CENTRE</u>				
FAREHAM				
Asset Ref.	Outlet	HOT °C	COLD °C	COMMENTS
GROUND FLOOR				
00036/00035	Kitchen	53.8	7.1	
00033	WC	57.5	7.2	
00031	Disabled WC	59.9	7.2	
FIRST FLOOR				
00030/00029	UNISEX WC	59.4	6.8	

<u>B&Q HOUSE</u>				
CHANDLERS FORD				
Asset Ref.	Outlet	HOT °C	COLD °C	COMMENTS
GROUND FLOOR				
09089/09088	Core 11 Cleaners	55.0	11.0	
09069	Main Kitchen	52.4	10.0	
00012/00013	Core 10 Tea	53.8	17.0	
0021/0020	Coffee Shop	58.6	12.8	
10204	Core 7 Tea	56.7	12.8	
10199/10200	Core 8 Cleaners	64.7	9.5	
10039	Core 9 Tea	68.5	13.0	
	Gym Ladies	55.6	37.9	12.5
	PLANT ROOM	FLOW	RETURN	
	Calorifier 1	64.0		
	Calorifier 2	58.0		INCREASE TO MIN 60°C

Asset Ref.	Outlet	HOT °C		COLD °C	COMMENTS
FIRST FLOOR					
09075/09074	Core 11 Cleaners	56.4		11.9	
10336/10337	Core 7 Cleaners	56.1		9.7	
10379	Core 7 Tea	54.4	48.0	15.0	
09078	Core 8 Tea	63.0	51.5	12.0	
10402	Core 9 Tea	63.1	50.0	11.2	
0016/0017	Core 10 Tea	58.4	49.1	19.9	
	Rest Room	40.8		20.0	INCREASE TO MIN 50°C
	C Kitchen 1	52.6		10.9	
	C Kitchen 2				
SECOND FLOOR					
09083/09082	Core 10 Tea	58.1	51.2	19.9	
09081/09080	Core 7 Cleaners	58.2		10.0	
0014/0015	Core 7 Tea	52.1	47.6	13.2	
09086/09087	Core 8 Tea	67.1	51.8	12.0	
09084/09085	Core 9 Tea	63.2	50.2	12.8	
Q/A LAB					
09093/09092	Cleaners Sink				
	Q/A Lab	ZIP OK			

Non Conformities are in Red

L8 recommends cold water should be stored and distributed at no more than 20°C.

L8 recommends that the hot water should be stored at a minimum of 60°C and achieve 50°C, obtainable at user outlets within one minute of opening.