

At the time of the monthly visit on **20/3/2018**, within one minute these **hot water** outlet temperatures were recorded and within two minutes these **cold water** outlet temperatures were recorded: -

<u>B&Q DATA CENTRE</u>				
FAREHAM				
Asset Ref.	Outlet	HOT °C	COLD °C	COMMENTS
GROUND FLOOR				
00036/00035	Kitchen	55.4	8.4	
00033	WC	56.8	8.5	
00031	Disabled WC	60.2	8.1	
FIRST FLOOR				
00030/00029	UNISEX WC	52.6	7.9	

<u>B&Q HOUSE</u>				
CHANDLERS FORD				
Asset Ref.	Outlet	HOT °C	COLD °C	COMMENTS
GROUND FLOOR				
09089/09088	Core 11 Cleaners	59.2	10.6	
09069	Main Kitchen	56.0	10.2	
00012/00013	Core 10 Tea	58.1	19.0	
0021/0020	Coffee Shop	59.1	12.7	
10204	Core 7 Tea	63.8	11.6	
10199/10200	Core 8 Cleaners	64.7	8.9	
10039	Core 9 Tea	68.0	11.5	
	Gym Men	56.2	40.3	12.0
	PLANT ROOM	FLOW		RETURN
	Calorifier 1	60.0		
	Calorifier 2	60.0		

Asset Ref.	Outlet	HOT °C		COLD °C	COMMENTS
FIRST FLOOR					
09075/09074	Core 11 Cleaners	57.8		10.9	
10336/10337	Core 7 Cleaners	59.4		9.6	
10379	Core 7 Tea	56.8	48.4	14.9	
09078	Core 8 Tea	62.5	52.0	9.6	
10402	Core 9 Tea	61.6	51.1	11.8	
0016/0017	Core 10 Tea	59.8	48.2	20.0	
	Rest Room	48.5		20.8	INCREASE HOT TO MIN 50°C FLUSH COLD TO BELOW 20°C
	C Kitchen 1	58.6		10.1	
	C Kitchen 2				
SECOND FLOOR					
09083/09082	Core 10 Tea	60.2	51.0	20.0	
09081/09080	Core 7 Cleaners	59.0		9.6	
0014/0015	Core 7 Tea	53.0	47.9	15.9	
09086/09087	Core 8 Tea	65.8	51.3	11.0	
09084/09085	Core 9 Tea	59.6	49.0	12.3	
Q/A LAB					
09093/09092	Cleaners Sink				
	Q/A Lab	ZIP OK			

Non Conformities are in Red

L8 recommends cold water should be stored and distributed at no more than 20°C.

L8 recommends that the hot water should be stored at a minimum of 60°C and achieve 50°C, obtainable at user outlets within one minute of opening.