



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Oakridge House NCU
Jefferson Road
Basingstoke
RG21 5QS

Customer: Hampshire County Council

Date: 27th June 2011

System Type and Location: Cold Water Storage Tank – Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: (hours) Chemical Level @ Start = 500ppm
Chemical Level @ 10 minutes = 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Oakridge House NCU
Jefferson Road
Basingstoke
RG21 5QS

Customer: Hampshire County Council

Date: 27th June 2011

System Type and Location: Cold Water Storage Tank – Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: (hours) Chemical Level @ Start = 500ppm
Chemical Level @ 10 minutes = 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION