



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001/BS8558:2011

**Site:** Solent Mead OPH  
Church Lane  
Lymington  
Hampshire

**Customer:** Hampshire County Council

**Date:** 20 August 2012

**System Type and Location:** New parts & fittings to Arjo Bath to Rowan Wing bathroom

**Disinfecting Product:** Sodium Hypochlorite Solution

**Contact Time:** Chemical Level @ start = 90 ppm  
Chemical level @ 30 minutes = 90 ppm  
Chemical Level @ 60 minutes = 90 ppm  
Chemical Level @ Finish = As Mains

**Scope of Work Completed:** System disinfected and flushed to BS8558:2011 specification

Freeston Water Treatment Limited 

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION