



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Bray Marina
Monkey Island Lane
Bray
SL6 2EB

Customer: M.D.L.

Date: 16th January 2013

System Type and Location: Cold Water Storage Tank No. 1
Toilet Block Loft Space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Bray Marina
Monkey Island Lane
Bray
SL6 2EB

Customer: M.D.L.

Date: 16th January 2013

System Type and Location: Cold Water Storage Tank No. 2
Toilet Block Loft Space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION