



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 14th January 2013

System Type and Location: Cold Water Storage Tank No. 1
Basin A Ladies Toilet Loft Space West

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk





Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 14th January 2013

System Type and Location: Cold Water Storage Tank No. 2
Basin A Ladies Toilet Loft Space East

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 14th January 2013

System Type and Location: Cold Water Storage Tank No. 3
Basin A Gents Toilet Loft Space West

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 14th January 2013

System Type and Location: Cold Water Storage Tank No. 4
Basin A Gents Toilet Loft East

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 15th January 2013

System Type and Location: Cold Water Storage Tank No. 5
Ladies Toilet Block Loft Space West

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 15th January 2013

System Type and Location: Cold Water Storage Tank No. 6
Basin B Ladies Toilet Block Loft Space East

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 15th January 2013

System Type and Location: Cold Water Storage Tank No. 7
Basin B Gents Toilet Loft Space West

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 15th January 2013

System Type and Location: Cold Water Storage Tank No. 8
Basin B Gents Toilet Loft Space East

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 15th January 2013

System Type and Location: Cold Water Storage Tank No. 9
Basin C Ladies and Gents Roof Space East

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Hythe Marina
Shamrock Way
Hythe Marina
Hythe S045 6DY

Customer: M.D.L.

Date: 15th January 2013

System Type and Location: Cold Water Storage Tank No. 10
Basin C Ladies and Gents Roof Space East (right)

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level at start = 500ppm
Chemical level at 10 Mins = 500ppm
Chemical level at Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION