



Certificate of Analysis

Freeston Water Treatment Ltd
 Unit 1, Lulworth Business Centre
 Nutwood Way
 Calmore Industrial Estate
 Southampton
 SO40 3WW

Sample Date: 13-Dec-12
 Received Date: 13-Dec-12
 Test Date : 14-Dec-12
 Certificate Ref: 143324-24/12/2012 12:46:44
 (4)
 Certificate ID: 466370
 Order Number: PO/PS
 SDG Reference: FWT_SOU 14-12-12 3
 Laboratory Reference: FWT_SOU[RM]766672
 Legionella Process Date: 14/12/2012

Sample : SP/PS/023
Details : Labs Copy

| Method Ref | Determination | Result | Units |
|------------|------------------------------|--------------|------------|
| *BP50.9 | Legionella spp. (Calculated) | N/A | cfu/l |
| BP50.9 | Legionella spp. | Not Detected | cfu/Volume |
| * | Volume Of Sample Filtered | 500 | ml |

Approved By: Nasir Maroof(Senior Analyst)

Date: 24-Dec-12

Abbreviations: < = Less than, > = Greater than. SDG = Sample Delivery Group. The site of test is identified by BH = Bellshill, which comprise the 0996 group. Method suffix denotes testing laboratory. Tests marked *, # or \$ in this report are not included in the ISO 17025 accreditation schedule for the UKAS testing laboratories 0996. Those marked: * have not been subcontracted and are not accredited; # have been subcontracted and are ISO 17025 Accredited; \$ have been subcontracted and are not ISO 17025 accredited; Comments, opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. For softened water supply, minimum concentrations apply for hardness (60mg/l as Ca) and alkalinity (30mg/l as HCO3). Method details and performance characteristics are available on request. The Legionella (calculated) det is a calculated det where the result is extrapolated from the Legionella test results. A N/A result for Legionella (calculated) indicates a calculation cannot be performed as Legionella was not detected. Tests marked ¥ have exceeded recommended time frame from sampling to analysis therefore the validity of results may be affected. Results identified by ~ have been estimated (counts on plates were outside statistical limits).



0996