



Freston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freston.co.uk
Web: www.freston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Westgate School
Cheriton Road
Winchester
SO22 5AZ

Date: 01 October 2012

System Type and Location: 2 x Cold Water Storage Tank – Old School Building, The Hub roof space above entrance

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start \geq 500ppm
Chemical Level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freston.co.uk



LEGIONELLA
CONTROL ASSOCIATION