



Freeton Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeton.co.uk](mailto:info@freeton.co.uk)  
Web: [www.freeton.co.uk](http://www.freeton.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Paternoster House  
Watermoor Road  
Cirencester  
Gloucestershire GL7 1JR

**Customer:** The Orders of St. John Care Trust

**Date:** 5<sup>th</sup> November 2010

**System Type and Location:** 2 Cold Water Storage Tanks Linked - Loft

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical level @ start = 500ppm  
Chemical level @ 10 mins = 500ppm  
Chemical level @Finish = As mains

**Scope of Work Completed:** ACoP L8

Freeton Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:  
[www.freeton.co.uk](http://www.freeton.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION