



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Coombs
The Gorse
Coleford
Gloucestershire GL16 8QE

Customer: The Orders of St. John Care Trust

Date: 5th January 2012

System Type and Location: Cold Water Storage Tank - Beech House Loft Space

Disinfecting Product: Chlorine Dioxide

Contact Time: (hours) Chemical level @ Start = 500ppm
Chemical level @ 10 mins = 500ppm
Chemical level @Finish = As mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Coombs
The Gorse
Coleford
Gloucestershire GL16 8QE

Customer: The Orders of St. John Care Trust

Date: 5th January 2012

System Type and Location: Cold Water Storage Tank – Holly House Loft Space

Disinfecting Product: Chlorine Dioxide

Contact Time: (hours) Chemical level @ start = 500ppm
Chemical level @ 10 mins = 500ppm
Chemical level @Finish = As mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Coombs
The Gorse
Coleford
Gloucestershire GL16 8QE

Customer: The Orders of St. John Care Trust

Date: 5th January 2012

System Type and Location: Cold Water Storage Tank – Oak Lodge Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: (hours) Chemical level @ start = 500ppm
Chemical level @ 10 mins = 500ppm
Chemical level @Finish = As mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Coombs
The Gorse
Coleford
Gloucestershire GL16 8QE

Customer: The Orders of St. John Care Trust

Date: 5th January 2012

System Type and Location: Cold Water Storage Tank – Main House Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: (hours) Chemical level @ start = 500ppm
Chemical level @ 10 mins = 500ppm
Chemical level @Finish = As mains

Scope of Work Completed: ACoP L8

Freeton Water Treatment Limited 

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeton.co.uk

