



Freeton Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeton.co.uk](mailto:info@freeton.co.uk)  
Web: [www.freeton.co.uk](http://www.freeton.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Coombs  
The Gorse  
Coleford  
Gloucestershire GL16 8QE

Customer: The Orders of St. John Care Trust

Date: 7<sup>th</sup> January 2013

System Type and Location: Cold Water Storage Tank – Main Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start  $\geq$  500ppm  
Chemical level @ 10 minutes  $\geq$  500ppm  
Chemical level @ finish = As Mains

Scope of Work Completed: ACoP L8

Freeton Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

[www.freeton.co.uk](http://www.freeton.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION