



# Certificate of Analysis

Freeston Water Treatment Ltd  
Unit 1, Lulworth Business Centre  
Nutwood Way  
Calmore Industrial Estate  
Southampton  
SO40 3WW

Sample Date: 13-Jun-11  
Received Date: 14-Jun-11  
Test Date : 14-Jun-11  
Certificate Ref: 20767-28/06/2011 09:48:22 (2)  
Certificate ID: 66121  
Order Number: CH0101/0102  
SDG Reference: FWT\_SOU 14-06-11 2  
Laboratory Reference: FWT\_SOU[LY]107696  
Legionella Process Date: 14/06/2011

Sample : CH0102

Method Ref	Determination	Result	Units
BP50.9	Legionella spp.	Not Detected	cfu/Volume
BP50.9	Legionella spp.	N/A	cfu/l
*	Volume Of Sample Filtered	500	ml

Approved By: Richard Shepherd(Lab Manager)

Date: 27-Jun-11

Page 1 of 1

Abbreviations: < = Less than, > = Greater than. SDG = Sample Delivery Group. The site of test is identified by RM = Rotherham, DB = Dublin, BH = Bellshill, which comprise the 0996 and 2300 groups. Method suffix denotes testing laboratory. Tests marked \*, # or \$ in this report are not included in the ISO 17025 accreditation schedule for the UKAS testing laboratories 0996 and 2300. Those marked: \* have not been subcontracted and are not accredited; # have been subcontracted and are ISO 17025 Accredited; \$ have been subcontracted and are not ISO 17025 accredited; Comments, opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. For softened water supply, minimum concentrations apply for hardness (60mg/l as Ca) and alkalinity (30mg/l as HCO3). Method details and performance characteristics are available on request. Results identified by ~ have been estimated (counts on plates were outside statistical limits).



0996