



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Wyatt House  
Matthews Way  
Stroud  
Gloucestershire GL5 4EE

**Customer:** The Orders of St. John Care Trust

**Date:** 6<sup>th</sup> March 2012

**System Type and Location:** Cold Water Storage Tank 1 – Roof

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical level @ start = 500ppm  
Chemical level @ 10 mins = 500ppm  
Chemical level @Finish = As mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited



.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:  
[www.freeston.co.uk](http://www.freeston.co.uk)





Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Wyatt House  
Matthews Way  
Stroud  
Gloucestershire GL5 4EE

**Customer:** The Orders of St. John Care Trust

**Date:** 6<sup>th</sup> March 2012

**System Type and Location:** Cold Water Storage Tank 2 – Roof

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical level @ start = 500ppm  
Chemical level @ 10 mins = 500ppm  
Chemical level @Finish = As mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:  
[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION