

Wendy Gibbs
 Freeston Water Treatment Ltd
 Unit 1, Lulworth Business Centre
 Nutwood Way
 Calmore Industrial Estate
 Totton
 Southampton

Certificate Of Analysis

Purchase Order: PO/JA/4530

Received on: 16/07/2013

Taken On: 16/07/2013

Taken By: J ALLEN

Sample Number	Sample Description	Legionella Colony Count (500 ml tested) cfu/litre MW7	Legionella not pneumophila Identification MW7	Legionella Pneumophila 1 Identification MW7	Legionella Pneumophila 2-14 Identification MW7
448-2013-00084478	1. JA/9507 Matrix: Tap water Sampling Time: 11:30:00	Not Detected	--	--	--



Report validated by Dhvani Shabu, Analytical Services Manager on 30/07/2013

Unless stated, all results are expressed on a sample as received basis.

☒ Indicates that this test did not commence within 24 hours of receipt of sample, during which time the sample has been refrigerated. The date displayed corresponds to the date the sample was prepared.

† Indicates that this test was subcontracted

* Indicates that this parameter is not included in the UKAS accreditation schedule for the laboratory for this matrix.

Sample and results marked with [Φ] on this certificate deviated from the standard procedures and as a consequence the reliability of the result may be affected.

Read certificate in conjunction with EUF-007a

Opinions and/or interpretations within this report are outside our accreditation scope.

Certificates may not be reproduced except in full and with the permission of the laboratory.

Key: cfu colony forming units
 < denotes less than
 > denotes greater than
 ~ estimated value
 MPN Most Probable Number



Eurofins Environmental Testing UK Ltd

28-32 Brunel Road
 Westway Estate
 Acton, London W3 7XR
 T +44 (0) 20 8222 6070
 F +44 (0) 20 8222 6080

Registered Office
 i54 Business Park
 Valiant Way
 Wolverhampton WV9 5GB
 Regd in England No: 5875169

www.eurofins.co.uk