



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Southfield House
Woolram Wygate
Spalding
Lincoln PE11 1PS

Customer: The Orders of St. John Care Trust

Date: 03 Sept 2013

System Type and Location: Hot & cold water system and associated outlets via the cold water storage tanks

Disinfecting Product: Chlorine Dioxide Solution

Contact Time: Chemical level @ Start ≥ 50 ppm
Chemical level @ 30 minutes ≥ 50 ppm
Chemical level @ 60 minutes ≥ 50 ppm
Chemical level @ Finish = as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION