



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Chipping Norton Community Hospital
London Road
Chipping Norton
Oxford OX7 5AU

Customer: The Orders of St. John Care Trust

Date: 05 October 2012

System Type and Location: Cold Water Storage Tanks 1 & 2 – lower ground floor roof space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ finish = as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION