



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Henry Cornish House  
London Road  
Chipping Norton  
Oxford OX7 5AU

**Customer:** The Orders of St. John Care Trust

**Date:** 05 October 2012

**System Type and Location:** Cold Water Storage Tanks 1 & 2 – 2<sup>nd</sup> floor roof space by dining room

**Disinfecting Product:** Chlorine Dioxide

**Contact Time:** Chemical level @ start  $\geq$  500ppm  
Chemical level @ 10 minutes  $\geq$  500ppm  
Chemical level @ finish = as mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Henry Cornish House  
London Road  
Chipping Norton  
Oxford OX7 5AU

**Customer:** The Orders of St. John Care Trust

**Date:** 05 October 2012

**System Type and Location:** Cold Water Storage Tanks 3 & 4 – 2<sup>nd</sup> floor roof space by dining room

**Disinfecting Product:** Chlorine Dioxide

**Contact Time:** Chemical level @ start  $\geq$  500ppm  
Chemical level @ 10 minutes  $\geq$  500ppm  
Chemical level @ finish = as mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION